



**PHOSPHONATE KIT**  
**DROP COUNT - CAS METHOD**  
**CODE 7625-01**

<b>QUANTITY</b>	<b>CONTENTS</b>	<b>CODE</b>
15 mL	Sodium Thiosulfate, 0.1N	6155-E
15 mL	*Hydrochloric Acid, 0.1N	*6323-E
15 mL	*Hydrochloric Acid, 1.0N	*6130-E
15 mL	Chrome Azurol S Indicator	3964-E
60 mL	Thorium Nitrate, 0.00132M	3965-H
1	Test Tube, 2.5-5-10-15-20 mL, glass, w/cap	0970-S
1	Pipet, plain, glass, w/cap	0371

\*WARNING: Reagents marked with an \* are considered to be potential health hazards. To view or print a Safety Data Sheet (SDS) for these reagents go to [www.lamotte.com](http://www.lamotte.com). Search for the four digit reagent code number listed on the reagent label, in the contents list or in the test procedures. Omit any letter that follows or precedes the four digit code number. For example, if the code is 4450WT-H, search 4450. To obtain a printed copy, contact LaMotte by email, phone or fax.

Emergency information for all LaMotte reagents is available from Chem-Tel (US, 1-800-255-3924) (International, call collect, 813-248-0585).

To order individual reagents or test kit components, use the specified code number.

## PROCEDURE

---

1. Fill test tube (0970-S) to 10 mL line with sample water.
2. Add 1 drop of Sodium Thiosulfate, 0.1N (6155).
3. Add 5 drops of Chrome Azurol S Indicator (3964). Cap and mix.
4. While gently swirling the tube, add \*Hydrochloric Acid, 0.1N (6323) one drop at a time, until yellow color changes through orange to pink (pH 4-5). If, after adding 20 drops, the solution has not changed to pink, begin adding the \*Hydrochloric Acid, 1.0N (6130) one drop at a time until the solution turns pink.
5. Use the pipet assembly (0371) to add Thorium Nitrate, 0.00132M (3965), one drop at a time, mixing after each drop, until the solution changes from pink to purple. Be sure to hold the pipet in a vertical position. Record number of drops.
6. Multiply the number of drops of Thorium Nitrate, 0.00132M (3965) used by the factor below to obtain the result in ppm phosphonate.

NOTE: For most accurate results, the test procedure should be run on a blank sample of Phosphonate-free water. This result should be subtracted from the reading obtained in Step 6.

<b>Phosphonate</b>	<b>Compound Name</b>	<b>Factor</b>
Dequest 2000	AMP(NTP)	1.5
Dequest 2006	NaAMP	1.9
Dequest 2010	HEDP(A)	1.25
Bayhibit AM	PBTC	1.4
Belcor 575	HPA	1.0
Belsperse 161	PCA	2.3

### LaMOTTE COMPANY

Helping People Solve Analytical Challenges

PO Box 329 · Chestertown · Maryland · 21620 · USA  
800-344-3100 · 410-778-3100 [Outside U.S.A.] · Fax 410-778-6394

Visit us on the web at [www.lamotte.com](http://www.lamotte.com)